



February 13, 2019  
**ADDENDUM NO. 2**

**Regarding: Project No. 90600  
SR 125 Improvements at Woodlands Drive  
Clermont County Transportation Improvement District**

**To All Bidders:**

Please be advised that the following revisions/clarifications have been made to the Bid Package:

**1. Section V, Bid Proposal and Bid Guaranty:**

The bid opening date of Thursday, February 14, 2019 shall be revised as follows:

**REVISED OPENING DATE SHALL BE TUESDAY, February 19, 2019 AT 2:00 P.M. LOCAL TIME**

**2. Clarifications:**

1. Sheet 57 of 80: WATER MAIN TRENCH DETAILS – Controlled Density Fill is only required to be used for trenches located under or within three feet of the edge of an EXISTING roadway. Controlled Density Fill will NOT be required in the areas of the new road construction.

**Please sign and return a copy of this letter by fax or mail to the Clermont County Engineer's Office prior to the bid opening at 2:00 P.M. local time on Tuesday, February 19, 2019 or with your bid documents at that time. Please complete the Bid Proposal, noting receipt of addendum.**

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Signature Owner/Agent

Mail To: Clermont County Engineer, Attn: Jeremy Evans, 2381 Clermont Center Drive, Batavia, Ohio 45103

Fax To: Clermont County Engineer, Attn: Jeremy Evans, (513) 732-8875