

9/25/2020

Questions and Answers to CCTID LOI – Roundbottom Road Bridge Replacement & Pond Run Road Bridge Replacement

Pond Run Road

- Will traffic be maintained on the bridge during construction or will a detour be used? **Detours will be used. Road Closed.**
- Can one-lane, two-way signalized traffic be used on SR-749 during construction? **Most Likely 2-way traffic with lights on SR 749 will be used.**
- Will any bank stabilization be required along SR-749 as part of this project? **Possibly. May want to extend wingwalls to protect the intersection and portions of SR 749. An evaluation during design will probably be discussed during scoping.**
- Does the CCTID want the large culvert adjacent to the bridge left undisturbed during construction or can the culvert headwall and end be modified, if needed? **An evaluation of the culvert condition will be discussed as part of the scoping.**
- Since there were no geotechnical prequalifications listed in the RFP, will CCTID be providing geotechnical information? **It is the intent that the consultant will sub out the geotechnical work.**
- Will CCTID be providing field survey? **The CCTID will probably provide survey information, however we will discuss further during the scoping.**
- Will the consultant be responsible for utility coordination? **Yes, the consultant will handle the utility coordination.**
- Does the County know of any flooding or hydraulic issues at the bridge? **None that we are aware of.**

Roundbottom Road

- Will traffic be maintained on the bridge during construction or will a detour be used? **Detours will be used. Road Closed.**
- Since there were no geotechnical prequalifications listed in the RFP, will CCTID be providing geotechnical information? **It is the intent that the consultant will sub out the geotechnical work.**
- Will CCTID be providing field survey? **The CCTID will probably provide survey information, however we will discuss further during the scoping.**
- Will the consultant be responsible for utility coordination, besides Clermont County Water Resources? **Yes, the consultant will handle the utility coordination, including coordination with the Clermont County Water Resources.**
- Will the consultant be responsible for RR coordination? **Yes.**
- Does the County know of any flooding or hydraulic issues at the bridge? **None that we are aware.**

9/28/20:

Questions and Answers to CCTID LOI – Roundbottom Road Bridge Replacement & Pond Run Road Bridge Replacement

- In response to your question relative to resumes being included as a part of the first 10 pages: Yes, any resumes as well as capacity of assigned staff and their workload may be included as part of the first 10 pages and does not have to be included as a part of the 2 page project approach.
- If you are submitting for both projects, 1 LOI submittal may be used with 10 pages for the LOI and 2 pages for each project approach for a total of 14 pages.

